



ADDENDUM NUMBER: 01

Buncombe County
Fleet Services Complex
Asheville, NC

CPL Project Number: 15716.00

April 10, 2023

This Addendum issued prior to receipt of Bid hereby becomes a part of the Construction Documents for the above project. All information contained in this Addendum supersedes and takes precedence over any conflicting information in the original Bidding Documents dated March 20, 2023 and all prior addenda.

CLARIFICATIONS FROM DESIGN TEAM

1. The Project Manual dated April 5, 2023 is included as an attachment to this addendum.
2. The mechanical drawing set dated March 20, 2023 is included as an attachment to this addendum.
3. Basis of Design information for the fuel tank / pump station noted on sheet C201 is included below. The delegated design for the fuel tank / pump station to include the foundation and/or concrete pad as noted on C201.
 - a. Basis of Design: Memco Inc. – EnviroSafe Above-Ground Fuel Systems
 - b. Model / Size: 10,000 Gallon Fireguard Tank Split 50/50 Mounted on Saddles (Diesel/Gasoline) with pump station.
 - c. Ladder with safety shield.
 - d. 50 feet of hose to pump station.
 - e. Electrical package for pumps and switches.
 - f. Envirolastic 940 DTM Polyaspartic Urethane for High Performance Finish.
 - g. Contact: Sam Judkins, Sales Engineer; 1-800-555-4754 Ext 136;
sam@envirosafetanks.com

QUESTIONS FROM CONTRACTORS

4. NONE

Attachments: Project manual
Mechanical drawings (H000, H201, H301, H501, H800, and H900)