



**ADDENDUM #2**

*June 15, 2023*

**TO: ALL POTENTIAL SUBMITTERS**

**FROM: RON VENTURELLA, BUNCOMBE COUNTY PROCUREMENT MANAGER**

**SUBJECT: ADDENDUM #1 FOR REOI LANDFILL GAS BENEFICIAL USE EVALUATION FOR THE BUNCOMBE COUNTY LADNFILL**

**Addendum # 2**

**The following questions were asked by potential bidders (listed in no particular order):**

Q-Can you please advise of the size of the existing Duke electrical interconnect for the power plant?  
A-The main breaker is rated at 15kv 12900 is the line voltage.

**END OF ADDENDUM #2**  
**REOI LANDFILL GAS BENEFICIAL USE EVALUATION FOR THE BUNCOMBE COUNTY LADNFILL**